

ADDENDUM NO. #1**ISSUE DATE: 04/29/2025**

The following changes and/or clarifications shall be incorporated into said Bid Documents, and such changes shall be allowed for in the Bid by the Contractor. The Bid Form shall represent the conditions as set forth in the original Bid Documents, as modified by this Addendum.

1. Add interior lighting to the pavilion. A total of 12 lamps (48" 60W LED Lighting, 3000K Lighting Temp) are to be surface mounted within the pavilion, evenly spaced. Contractor to provide separate circuits for lighting and remaining power for the pavilion.
 - a. Revised notes on CP-04.
 - b. Included schematics of lighting layout on CP-05.
 - c. Pricing for lighting/electrical work to be included in pricing for existing bid items "5040 SF Open Air Pavilion" or "Electrical Service for Pavilion".

Bidder shall acknowledge receipt of this ADDENDUM NO. #1 in the designated area on the provided Bid Form documentation prior to the Bid due date.