



**Lori M. Stone, Mayor**

Purchasing Division  
Office of the Controller  
One City Square, 4<sup>th</sup> Floor  
Warren, Michigan 48093-5289

Phone (586) 574-4639  
FAX (586) 574-4614

## ADDENDUM 5

**ITB-W-1478**

**APRIL 29, 2025**

REGARDING

### CONSTRUCTION OF NEW WARREN LIBRARY

**PLEASE BE ADVISED** that the Contractor is required to acknowledge all addendum on Page 004100 -1 of the Bid Form. The bid document does not allow enough slots to acknowledge all addenda. Therefore, the Contractor shall add a slot for any addenda that does not currently have one. The Contractor shall then initial and date the addendum on Page 004100 – 1 to acknowledge receipt of the addendum.

**PLEASE, ALSO BE ADVISED** of the following City responses to Vendor questions.

- Q1. Can you clarify the following statement from Addendum #3? "All Furnishings, Fixtures, and Equipment are by Owner. Contractor is responsible for coordination during installation." Does this include plumbing fixtures?
- R1. The Plumbing fixtures are by Contractor. FFE (furnishing, fixtures, equipment) is an abbreviation for furniture type fixtures that the City will be responsible for providing.
- Q2. Please advise when the design for the gated enclosures will be available.
- R2. There will be a few drawing-related items that will be released as a Bulletin after a contractor has been awarded the job. The construction detail for the garbage enclosure is one of these items. The updates will not have an impact on cost, and are more clarifications or further coordination.
- Q3. Please clarify if the HVAC ductwork needs to be painted and to what specification.
- R3. To clarify, the exposed ductwork will not be painted.

Sincerely,

Craig Treppa  
Purchasing Agent

Acknowledged by: \_\_\_\_\_

Company Name: \_\_\_\_\_